

File Copy

**SPRINGHILL COMPRESSOR STATION
ENGINES 4 AND 5
EMISSION TEST REPORT
LAUREL MOUNTAIN MIDSTREAM, LLC
LAKE LYNN, PENNSYLVANIA**

Primary Facility ID: 719219

Test Date: October 13, 2015

Report Date: October 22, 2015

Prepared for:

Williams Companies, Inc.
Park Place 2, 2000 Commerce Drive
Pittsburgh, PA 15275

Prepared by:

Technical Compliance Solutions LLC
158 Wilson Drive
Dante, VA 24237
(412) 527-3475



PA Lab Registration No. 03-05412

Project No. 5.15.041

**SPRINGHILL COMPRESSOR STATION
ENGINES 4 AND 5
EMISSION TEST REPORT
LAUREL MOUNTAIN MIDSTREAM, LLC
LAKE LYNN, PENNSYLVANIA**

1 TEST RESULTS SUMMARY

PADEP General Permit Number: GP5-26-00587C				Test Date: October 13, 2015	
Source Name: Engine 4					
Pollutant	Units	Average Result	JJJJ Limit	Permit Limit	Compliant / Non-Compliant
Carbon Monoxide	ppm _{dv} @15%O ₂	6.47	270	47	Compliant
	lb/hr	0.15	NA	0.52	Compliant
	g/bhp-hr	0.05	2.0	0.17	Compliant
Nitrogen Oxides	ppm _{dv} @15%O ₂	31	82	NA	Compliant
	lb/hr	1.19	NA	1.52	Compliant
	g/bhp-hr	0.43	1.0	0.50	Compliant
VOCs (excluding HCHO)	ppm _{dv} @15%O ₂	3.5	60	NA	Compliant
	lb/hr	0.13	NA	0.76	Compliant
	g/bhp-hr	0.045	0.7	0.25	Compliant
HCHO	lb/hr	0.10	NA	0.15	Compliant
	g/bhp-hr	0.035	NA	0.05	Compliant